

Competitive Sealed Proposal (CSP) No. P18005 (6/13/18)
Gas Shutoff Valve Replacement/Installation at La Armada I & II

Addendum #4

July 20, 2018

Request for Competitive Sealed Proposals (CSP) No. 18005 – Gas Shutoff Valve Replacement/Installation at La Armada I & II is hereby amended as follows:

1) Clarification on type of valves:

The Scope of Work is calling for Broen Ballomax pipeline valve, straight ball, 285 MAOP, ANSI 150 Weld x Weld (arc weld method), 285 psi, catalog number as noted :

2".....2BMW285PLFPSB145

4".....4BMW285PLFPSB145

6".....6BMW285PLFPSB145

Or approved type.

Note: The valve body is made of Carbon steel and the Ball is made of Stainless Steel.

All other terms and conditions of the Request for Competitive Sealed Proposals remains unchanged. **The signed addendum must be returned with your CSP submission.**

Acknowledged and accepted:

Company: _____

Representative Name: _____

Signature: _____

Date: _____

