

**Corpus Christi Housing Authority**  
**Addendum #1 to:**  
**Request for Competitive Sealed Proposal (CSP) NO. P19003 (1/11/19)**  
**Light Pole Replacements (Sea Breeze)**

January 28, 2019

Request for Competitive Sealed Proposals (CSP) No. 19003 – Light Pole Replacements (Sea Breeze) is hereby amended as follows:

- 1) The Scope of Work references sever different types of poles (i.e. steel, aluminum and fiberglass). Only bid aluminum poles, satin finish, 25 foot tall, .250 material thickness, 5" O.D., square plate support 8"x8"x3/4" bold consistent with existing square bold pattern with concrete supporting pier or approved equal.
- 2) The Scope of Work specifies a 150 watt cobra head on 4' arm. Bid on LED 150 watt NextGen 2 parking lot lights, 20,000 lumens 5000 K – arm mount, with photocell or approved equal. Arm extender can be less than 4'.
- 3) Please clarify if the intent is to only illuminate roadway and parking areas, different distribution types may be required in certain areas to avoid light wash and unwanted area. The dual lights parallel to drive are suitable for driver lighting, and singular LED light should be suitable for parking lot area. Unwanted light should not be placed to interfere with tenant windows.

All other terms and conditions of the Request for Competitive Sealed Proposals remains unchanged. **The signed addendum must be returned with your CSP submission.**

Acknowledged and accepted:

Company: \_\_\_\_\_

Representative Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

