CORPUS CHRISTI HOUSING AUTHORITY & AFFILIATES RFQ #19009 - Patio Fence Replacement - Addendum #2

Date: April 4, 2019

Request For Quotations (RFQ) No. 19009 – Patio Fence Replacement at Alaniz, is hereby amended as follows:

- (1) Question: Do you want to include gates in the new fence? Answer: No.
- (2) Do you want to post bases shimmed to eliminate the slant?

 Answer: Post bases are to be vertical and augured with concrete in the ground around the outside of the patio slab.
- (3) Do you want a rot board at the bottom of the fence? Answer: No. Install with top, middle and lower horizontal brace railings.
- (4) You call for treated cedar material. It has to be either cedar or treated, so which one do you want?

Answer: Treated pine to be used for posts and brace railings. Pickets are to cedar dog ear 1" x 6'.

(5) Instead of anchoring to concrete, can the new fence be installed in the dirt? Answer: Design was changed to install posts in dirt around patio slab in Addendum #1.

All other terms and conditions of the Request For Quotations remains unchanged. **The signed addendum must be returned with your RFQ submission.**

Acknowledged and accepted:	
Company:	
Representative Name:	— Corpus Christi—
Signature:	HOUSING
Date:	AUTHORITY