

CORPUS CHRISTI HOUSING AUTHORITY & AFFILIATES
IFB 20010 - Dumpster Enclosures and Sidewalk Improvements- Various Locations-
Addendum #2

Date: April 17, 2020

Invitation For Bids (IFB) No. 20010 – Dumpster Enclosures and Sidewalk Improvements – Various Locations, is hereby amended as follows:

1. Q - For the sidewalk improvements, the 4x4 wire mesh what gauge and does it have to be and does it have to be galvanized or will standard grade mesh work?
A – The proposed steel wire 4” x 4” wire mesh for sidewalks is galvanized, 18 gage, comes in a 48” x 100’ roll, from local vendors.

All other terms and conditions of the Solicitation remains unchanged. **The signed addendum must be returned with your IFB submission.**

Acknowledged and accepted:

Company: _____

Representative Name: _____

Signature: _____

Date: _____

