CORPUS CHRISTI HOUSING AUTHORITY & COASTAL HOUSING PARTNERS
IFB 27001 - HVAC Ductwork Replacement and Ceiling Restoration at Andy Alaniz - Addendum #1

Date: October 28, 2026

Request for Proposals (IFB) 27001 - HVAC Ductwork Replacement and Ceiling Restoration at Andy Alaniz, is hereby amended as follows:

1. Question: Approximately how big will the hole be per duct drop that will have to be patched?
   Answer: As per the SOW drywall removal will be as necessary for removal and new installation.

2. Question: Are we going to paint the ceiling corner to corner or just the patched area? Answer: Tape, Float Texture, and paint will be in area of work, to match existing.

3. Questions: Will there be a schedule provided as to how many buildings over how many days, or is the property vacant and we can just go at our own speed? Answer: Units will not be vacant, and an operational HVAC system will be necessary at the end of every day. There are 30 units included in the SOW and there will be a number of days included in the contract to complete SOW.

All other terms and conditions of the Solicitation remain unchanged. **The signed addendum must be returned with your IFB submission.**

Acknowledged and accepted:

Company: _____

Representative Name: _____

Signature: _____

Date: _____